

Fire Protection and Life Safety in Buildings and Transportation Systems

Organised by



Sponsored by



Ministerio de Cantabria (Ministerio)

With the collaboration of



University of
Edinburgh (UK)



Carleton University
(Canada)



University of
California
Berkeley (USA)



University of
Maryland (USA)



University of
Canterbury
(New Zealand)

With the support of



National Fire Protection
Association - NFPA



Society of Fire Protection
Engineers - SFPE



International Association for
Fire Safety Science - IAFSS



AVAILABLE FROM

GIDAI - Fire Safety - Research and Technology
UNIVERSITY OF CANTABRIA
Ave. Los Castros, s/n. 39005 Santander, Spain
Fax +34 942 202276 E-mail gidai@unican.es
<http://grupos.unican.es/GIDAI>

ISBN 978-84-8102-559-0

This Advanced Research Workshop was organized by:

GIDA – Fire Safety – Research and Technology
UNIVERSIDAD DE CANTABRIA
Dpto. de Transportes y Tecnología de Proyectos y Procesos
Avda. Los Castros, s/n
39005 Santander, Spain
Tel. + 34 942 201626. Fax. +34 942 202276; gida@unican.es;
<http://www.unican.es/GIDA>

With the collaboration of:

Society of Fire Protection Engineers
SFPE

National Fire Protection Association
NFPA

International Association for Fire Safety Science
IAFSS

Scientific Committee - Editorial Board:

Jorge A. Capón	University of Cantabria (Spain)
Daniel Alvaré	University of Cantabria (Spain)
Richard Conzel	University of Edinburgh (UK)
Michael Delichatsios	University of Ulster (UK)
Carlos Fernández-Pello	University of California, Berkeley (USA)
Charles M. Fleischmann	University of Canterbury (N. Zealand)
George Hadjipaphadriou	University of Carleton (Canada)
Morgan J. Hurley	SFPE (USA)
Timo Korhonen	VTT (Finland)
James A. Milke	University of Maryland (USA)
Frederick W. Mowrer	University of Maryland (USA)
Paulo Piloto	Instituto Pol. de Bragança (Portugal)
David Pinner	Harford Environment Research (UK)
James G. Quintiere	University of Maryland (USA)
Guillermo Rein	University of Edinburgh (UK)
José L. Torero	University of Edinburgh (UK)
Arnaud Trounev	University of Maryland (USA)

Sponsored by:



MINISTERIO
DE CIENCIA E
INNOVACIÓN

Consejería de Ayudas para la realización de Proyectos de Investigación,
Programas de Actividad Investigadora y Acciones Complementarias
Ref.: BIA2009-05701-E

Contents

	<u>Page</u>
Index.....	i
Preface.....	iii
Invited Lecture: Prescribing the Input for the Aset versus Rset Analysis: is this the way forward for Performance Based Design?.....	1
Application of Human Behaviour and Toxic Hazard Analysis to the Validation of CFD Modelling for the Mont Blanc Tunnel Fire Incident.....	23
Fire Behaviour and Façade Flames for Corridor and Tunnel Like Enclosures Fires.....	59
Analysis of Eleven Evacuation Events in Finland.....	75
Experiments to Investigate Radiant Heat Flux on Adjacent Buildings.....	87
Thermal Analysis in Fire-Resistance Furnace.....	103
Low and Medium Power Full-Scale Atrium Fire Tests and Numerical Validation of FDS.....	113
Loading Distance of Droplets from Water Mist Suppression Systems in Tunnels with Longitudinal Ventilation.....	139
Modelo Estocástico de Evacuación para Trenes de Pasajeros.....	155
Influence of the Bench Scale Test in the Calculation of the Heat Release Rate for Aircraft Materials: Cone Calorimeter vs. OSU Apparatus.....	185
Effectiveness Assessment of Road Tunnel Fire-Fighting Strategies by Ventilation and Water Mist Systems.....	197
Can Active Fire Protection Systems in Tunnels Prevent Minor Fire Incidents from becoming Disasters?	221

Numerical Simulations of Some Possible Fire Scenarios in a Closed Car Park with RANS and LES	233
Modelling of pedestrian movement around 90° and 180° bends.....	243
Experimental Research - Large-Scale Tunnel Fire Tests and the use of CFD modelling to predict Thermal Behaviour	258
An Experimental Review of the Homogeneous Temperature Assumption in Post-Flashover Compartment Fires.....	273
Psicosociología aplicada a Equipos de Intervención en Situaciones de Emergencia	295
Estabilidad ante el Fuego de la Estructura Metálica de Cubierta del Edificio Intermodal de la Nueva Terminal T1 del Aeropuerto de Barcelona	307
The Regulatory Use of Advanced Fire Engineering Techniques.....	323
Human Behaviour in case of Fire inside a Urban Tunnel through Computer Modelling...	349
Comparison of STEPS and FDS+EVAC Simulations to an Evacuation of a 5-Storey Building	363
An Immersive Simulation of Fire Evacuation Based on Virtual Reality	385
The Smoke Layer Interface during a Fire in an Atrium: a New Method to Locate it using a Zone Computer Model	397

Thermal Analysis in Fire-Resistance Furnace

Piloto, P.A.G.¹, Mesquita, L.M.R.¹, Alexandre Pereira²

¹ - Applied Mech. Dep., Polytechnic Inst. of Bragança, Campus Sta. Apolónia,
5301-857 Bragança, Portugal

² - Fellow research, Polytechnic Inst. of Bragança, Campus Sta. Apolónia,
5301-857 Bragança, Portugal

ABSTRACT

Fire resistance rating of building construction elements is defined under fire-resistance test furnace. The geometry and shape of fire-resistance furnaces is not defined by any prescriptive document, being necessary to comply thermally with specified nominal fire curves, such as ISO 834 or hydrocarbon [1,2].

This research work intends to measure temperatures inside furnace volume, using sixteen plate thermocouples to compare average temperature in four planes. Those planes are compared with reference thermocouple which is responsible for controlling furnace operation, see figure 1. Three tests were performed, the first two running with ISO 834, during 45 minutes and the last one running with hydrocarbon curve, during 30 minutes. Experimental results demonstrate that relative temperature differences are smaller than 30 % in the initial test stage, being smaller than 5 %, after 500 [s] until the end of the tests.

The numerical simulations were performed using Fluent CFD, using the structured finite volume mesh method. The Eddy Dissipation Model (EDM) was used for chemical species transport and reacting flow. The governing equations for mass, momentum and energy were solved for the three dimensional unsteady incompressible flow, with radiative heat transfer and turbulence model. The numerical results agree well with experimental results, being the relative temperature difference smaller than 5% for each nominal test. Numerical simulation also reveals the localized effect of each burner.

1 INTRODUCTION

The thermal performance of fire-resistance furnace is investigated. Furnace environment is normally considered homogeneous and with uniform temperature distribution, following specified nominal temperature evolution. Tests were conducted at the Polytechnic Institute of Bragança laboratory (LERM) using the 1 cubic meter fire-resistance furnace. This small furnace is suitable for initial validation of experimental temperature measurements. The furnace has 4 propane burners with 90 [kW] maximum power each, reference Kroenschroder BIO 65 HM-100/35-72/8. This furnace complies with European Standard EN 1363-1, considering the maximum deviation between reference temperature and the theoretical specified nominal curve for temperature.

Four planes were defined to evaluate the furnace temperature performance. Four plate thermocouples define each plane. Plane X150 and X850 are parallel to the exhaust zone while plane Z150 and Z850 are parallel to the transversal plane of burners.




Fig. 1. Model for fire-resistance furnace.

Three tests were performed. The first two tests used ISO834 nominal fire curve, defined by equation (1), while the last one used hydrocarbon nominal fire curve (2). In these equations, θ_a represents reference furnace temperature for time t , during testing conditions.

$$\theta_a = 20 + 345 \times \log_{10}(8t + 1) \quad [\theta_a (^{\circ}\text{C}); t(\text{min})] \quad (1)$$

$$\theta_a = 20 + 1080 \times (1 - 0.325 \times e^{-0.183t} - 0.675 \times e^{-1.2t}) \quad [\theta_a (^{\circ}\text{C}); t(\text{min})] \quad (2)$$

The thermal performance is determined by the comparison between average plane temperatures with reference furnace temperature, which represents each nominal fire curve.

Numerical simulations are also performed, using computational fluid dynamics, to evaluate thermal performance and validate experimental tests.

2 EXPERIMENTAL TESTS

The fire-resistance furnace was instrumented with 16 plate thermocouples, suspended at insulated slenderness steel frame, see figure 2. Plate thermocouples fulfil standards and were positioned according to the vertex position of 700 [mm²] cube, centered inside furnace.




Fig. 2. Plate thermocouple instrumentation.

Thermocouple control is achieved by matching the measured thermocouple temperature with the prescribed nominal fire curve. However, since thermocouples irradiate heat, they adjust themselves to the temperature at which there is a balance between the convection and net radiative heat transfer, [3]. Plate thermocouple is a stainless steel plate with $100 \text{ [mm}^2\text{]}$ and $0.7 \pm 0.1 \text{ [mm]}$ thick. The emissivity was considered greater than 0.7. The wire thermocouple is positioned on the back face, screwed with a small plate and insulated with ceramic fibre, [1].

Measurements were performed with multi-channel data acquisition system, MGCplus from HBM, with frequency equal to 0.1 [Hz] . Results were averaged from 4 plate thermocouples for each plane. Plane X850 was defined by the average temperature readings on TF1, TF2, BF1, BF2. Plane X150 was defined by the average temperature readings on Tb1, Tb2, Bb1, Bb2. Plane Z850 was defined by the average temperature readings on TFL, BFL, Tbl, Bbl, while Plane Z150 was defined by the average temperature readings on Tbr, TFR, BbR and BFR.

Figure 3 represents each measured temperature with plate thermocouple and the reference temperature for furnace.

The relative difference between each average plane temperature and reference temperature from furnace is below 5%, after the initial testing phase, corresponding to 500 [s]. Higher relative difference is expected before, due to higher temperature variation with time.

The exhaust temperature was also measured for test 1. There was a constant temperature difference between the reference furnace temperature and the temperature measured at the exhausts. This temperature was measured with an insulated welded thermocouple without plate an insulation protection. This explains the oscillating registry.




Fig. 3. Experimental results for temperature measurements and relative temperature deviations for each plane.

3 NUMERICAL SIMULATION

The numerical simulations were performed with Fluent software, using the finite volume method, [4]. The generalized Eddy Dissipation Model was used to simulate the combustion of propane-air mixture. This model is based on the assumption that chemical reaction is almost instantaneous, when compared with the chemical species flow transportation. The combustion was modelled using a global one-step reaction mechanism, assuming complete conversion of the propane to the product species of equation 3.



The reaction will be defined in terms of stoichiometric coefficients, formation enthalpies and parameters that control the reaction rate. The pressured based solver was used with unsteady and first order implicit formulation. The viscous model "K-Epsilon" with two equations and a standard wall function for near wall treatment was used. The surface to surface radiation model was used with computed view factors. The emissivity value for the internal wall furnace was considered equal to 0.7.

The use of constant transport properties for viscosity, thermal conductivity and mass diffusivity coefficients is acceptable because the flow is fully turbulent, see tables 1 and 2, [4]. The molecular transport properties will play a minor role compared to turbulent transport. The assumption of temperature dependent specific heat is an important key factor to predict more realistic peak flame temperature.

Specific heat	Mixing law	[J/kgK]
Conductivity	0.0454	[W/mK]
Viscosity	1.72×10^{-4}	[Kg/ms]

Table 1. Properties for propane-air mixture, [4].

Specific mass	1.225	[kg/m ³]
Specific heat	1005.43	[J/kgK]
Conductivity	0.0242	[W/mK]
Viscosity	1.7894×10^{-5}	[Kg/ms]

Table 2. Air properties, at reference temperature, 298 [K], [4].




Fig. 4. Variation of specific heat of the products and reactants [4].

The specific heat considered for mixture will be higher where the propane is concentrated, near the fuel inlet and where the temperature and combustion product concentration should be higher, see figure 4 for temperature dependence.

The governing equations for mass momentum and energy conservation are defined by equations 4-6.

$$\frac{\partial}{\partial t}(\rho Y_i) + \nabla \cdot (\rho \vec{v} Y_i) = -\nabla \cdot \vec{J}_i + R_i \quad (4)$$

Where ρ represents the specific mass, \vec{v} the velocity vector, Y_i is the local mass fraction that corresponds to the species " i ", \vec{J}_i the diffusion flux, while R_i represents the rate of each species formation by chemical reaction.

For the momentum conservation equation, the static pressure is defined by p , while $\vec{\tau}$ represents the stress tensor.

$$\frac{\partial}{\partial t}(\rho \vec{v}) + \nabla \cdot (\rho \vec{v} \vec{v}) = -\nabla p + \nabla \cdot \vec{\tau} \quad (5)$$

For the energy equation, E represents the energy value, k_{eff} the effective value for conductivity, T the temperature value, h_i the sensible enthalpy, while S_i represents the energy value from chemical reaction.

$$\frac{\partial}{\partial t}(\rho E) + \nabla \cdot (\vec{v}(\rho E + p)) = \nabla \cdot \left(k_{eff} \nabla T - \sum_i h_i \vec{J}_i + (\vec{\tau}_{eff} \cdot \vec{v}) \right) + S_i \quad (6)$$

An adiabatic condition was assumed in the internal furnace walls. The inlet thermal conditions were specified at room temperature. The exhaust temperature products were defined with information from experimental measured data.

The time dependence inlet velocity for air and propane were kept in proper ratio, during each test. Those values were defined according to the manufacturer limiting values, because they were not measured.

To solve the unsteady solution, the initial conditions were defined and an incremental time step was specified. An iterative process was used to solve discretized equations.

The numerical model was built with a structured mesh, using 125840 hexahedra finite volumes, each with 0.02[m] length side, see figure 5. Major simplification was introduced into the four burners, using the hydraulic diameter as reference value. Four inlet gas zones were defined concentric with the same number of air inlet zones, with dimension equal to 20x20 [mm] and 60x60 [mm], respectively. The exhaust is well identified at the bottom of the furnace volume, with rectangular dimensions equal to 100 x 400 [mm].




Fig. 5. Model for fire-resistance furnace.

Flame temperature depends on several factors during the combustion process and affects, significantly, heat transfer inside fire-resistance furnace. The rate of heat transfer increase with flame temperature. Figure 6 represents temperature and velocity, during the simulation of test 1, in different defined planes, in particular X150, X850, Z150, Z850 and exhaust. The burner B3/B4 plane is also represented.




Fig. 8. Numerical results for Test 1.

The flux of species is descendent, with small vortices zones, as can be seen in figure 6b) and d). The numerical results allow identifying the localized effect of each burner. The experimental measurements corroborate this evidence.

To determine the thermal performance of the numerical simulation, the mass average temperature value was determined for each plane defined for experiments, using equation (7). This average value is also compared with the reference value of the fire-resistance furnace, determining the relative difference, see figure 7.

$$\bar{T} = \frac{\int_V \rho \bar{v} d\bar{A}}{\int_V \rho d\bar{A}} \quad (7)$$




Fig. 7. Average temperature value inside furnace and relative temperature difference.

ACKNOWLEDGMENT

The authors acknowledge the financial support from the Portuguese Science and Technology Foundation, under the reference project PTDC/EME-PME/64913/2006.

REFERENCES

1. AENOR, Norma UNE 1363: Fire resistance test. Part 1: General requirements, 2000.
2. AENOR, Norma UNE 1363: Fire resistance test. Part 2: Alternative and additional procedures, October 2000.
3. S.Welch, pu Rubini, "Three dimensional simulation of a fire resistance furnace", Proceedings of 5th International Symposium on Fire Safety Science, Melbourne, Australia, ISBN 4-9900625-5-5 International Association for Fire Safety Science (IAFSS), pp1009-1020, March 1997.
4. FLUENT 6.3 Documentation, users manual, 2006.
5. Giuliano Gardolinski Venson, Gilberto Augusto Arnado Moreira, José Eduardo Mautone Barros, Ramón Molina Valle. "Modelagem do Perfil de Temperatura em Câmara de Combustão Tubular Utilizando o Modelo de Combustão Eddy Dissipation", *X Encontro de Modelagem Computacional*, Instituto Politécnico/UERJ - Nova Friburgo/RJ, 21 a 23 de Novembro 2007.
6. Coelho, P. J. "Numerical simulation of a mild combustion burner", Combustion and flame, 124: 503-518, Elsevier, 2001.
7. Welch, S; Rubini, P.; "Three dimensional simulation of a fire-resistance furnace", Proceedings of 5th International Symposium on Fire Safety Science, Melbourne, Australia, March 1997, International Association for Fire Safety Science, pp. 1009-1020, ISBN 4-9900625-5-5